

**Government of Andhra Pradesh**  
**A.P. State Disaster Response and Fire Services Department**

**Periodical Renewal Fire Certificate**

From:  
District Disaster Response & Fire Officer  
Andhra Pradesh, Srikakulam

To:  
The District Educational Officer,  
Srikakulam.,

**File No: 34776/SKL/DFO/2026, Date:11/09/2026**  
**Occupancy NOC RC Number: 586/DFO/SKL/2014**

Sir,

Sub: Andhra Pradesh State Disaster Response and Fire Services Department - Periodical Fire Certificate to the existing Non Multi Storeyed Building of **J M J Enlish Medium High School, represented by Correspondent, 2-67, Matam Kanchali, Kanchali Mandal, Srikakulam District** - Regarding.

- Ref:
1. G.O.Ms.NO.218 Home (Prisons & Fire) Department, Dated.22-12-2023
  2. This Office Delegation of Powers Rc.No.3350/Audit/NOC/2012, Dated.01-09-2025.
  3. This Office NOC for Occupancy Rc No. 586/DFO/SKL/2014, Dt.25/10/2014
  4. Renewal NOC For Occupancy 586/DFO/SKL/2014, Dt.25/01/2024
  5. Online Application for Renewal NOC of Correspondent, 2-67, Matam Kanchali, Kanchali Mandal, Srikakulam District - Inspection report called for Regarding.
  6. Online Inspection Report submitted by Officers of this Department on 11-09-2026.

-- X --

The Management of J M J Enlish Medium High School, represented by Correspondent, 2-67, Matam Kanchali, Kanchali Mandal, Srikakulam District has requested to issue Periodical Fire Certificate duly remitting the Fire Precautionary fee for Rs.51453/- vide challan No. 10108081282026, Dated 11/09/2026 at ONLINE, ONLINE.

J.M.J Enlish Medium High School

2. The builder has constructed a Non Multi Storeyed Building with Ground Floor + 2 Upper Floors with a height of 9.8 Mtrs for Educational Occupancy (Category - B1) in a total plot area of 9631.86 sq. meters.
3. Open Spaces:

***NOTE: It is the responsibility of the local Municipal authorities i.e., Municipal Corporations, Panchayats, IALA, SEZ , APIIC etc., to ensure the setbacks as per local building rules are in force vide G.O.Ms.No.44 Home (Prisons & Fire) Department Dated:12-03-2024.***

4. The builder has provided the following means of escape:

| Sl    | Details of Staircases | Required Nos / Meters as per NBC | Provided Nos / Meters |
|-------|-----------------------|----------------------------------|-----------------------|
| 1     | Internal Staircases   | Min 1 No. - 1.5 Meters           | 1 No. - 2.00 Meters   |
| 2     | External Staircases   | Min 1 No. - 1.5 Meters           | 1 No. - 1.25 Meters   |
| Total |                       | 3 Meters                         | 3.25 Meters           |

## 5. Occupant Load :

| Sl | Floor | Built up area (Sq Mtrs) | Occupancy Type | No of Occupants as declared by the builder | No of Occupants as per NBC | Aggregate width of Staircases Required (Meters) | Aggregate width of Staircases Provided(Meters) |
|----|-------|-------------------------|----------------|--------------------------------------------|----------------------------|-------------------------------------------------|------------------------------------------------|
| 1  | GF    | 689.05                  | Educational    | 171                                        | 171                        | 1.71                                            | 3.25                                           |
| 2  | FF    | 689.05                  | Educational    | 171                                        | 171                        | 1.71                                            | 3.25                                           |
| 3  | SF    | 689.05                  | Educational    | 171                                        | 171                        | 1.71                                            | 3.25                                           |
|    | Total | 2067.15                 |                | 513                                        |                            |                                                 |                                                |

6. The minimum Fire Fighting Installations required and provided as per Table 7 of Part 4 of National Building Code of India 2016 are:

| Sl | Fire Fighting Equipment | Provided   |
|----|-------------------------|------------|
| 1  | Fire Extinguishers      | 21 Nos.    |
| 2  | Hose Reel Systems       | 3 Nos.     |
| 3  | Terrace Tank            | 20000 Ltrs |
| 4  | Booster Pump            | 450        |

- Provide ABC 5 kg/6 kg fire extinguishers

7. This certificate is being issued as per G.O.Ms.No:218,Home(Prisons & Fire),Dt:22-12-2023

8. The No Objection Certificate for Occupancy was issued vide reference cited (3) and the Management has also obtained Periodical Renewal Fire Certificate vide reference 4th cited to the existing Non Multi Storeyed Building.

9. The Officers of the department have recommended to issue The Periodical Renewal Fire Certificate **Correspondent 2-67, Matam Kanchali, Kanchali Mandal, Srikakulam District** , subject to the following conditions.

| Sl | As Builder                                                                                                                                           | As Occupant                                                                                                    | As Security Personnel                                                                                                                                            |
|----|------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| 1  | All the fire protection arrangements shall be maintained in good condition as seen during inspection.                                                | All the escape/exit routes shall not be kept locked/blocked or encroached                                      | All the occupants must know the correct method of operation of the fire fighting system installed.                                                               |
| 2  | Any loss of life or property due to non-functioning of fire safety measures and other installations shall be the responsibilities of the management. | All occupants shall be trained to operate the fire safety equipments during emergency.                         | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.                                                      |
| 3  | Addition / alteration, if any in the building may be verified by building authority.                                                                 | Mock drills should be conducted once in 3 months for initial two years. Thereafter, once in every 6 months.    | All security personnel shall be trained to operate the fire safety equipments during emergency.                                                                  |
| 4  | This is Only for Fire Safety Point of View.                                                                                                          | Raise the alarm if the fire cannot be controlled; Evacuate the area completely at once with nearest safe exit. | Attack the fire using available fire equipment only if you feel capable of controlling. If not, take all steps to isolate the area by closing doors and windows. |

10. The applicant/management must train 40% of their total work force on 3 days Basic Firefighting Course under AP Fire Services and Civil Defence Training Institute, Sattenapalli or Regional Training Centres of the Department.

11. This Periodical Renewal Fire Certificate is valid from 11/09/2026 to 10/09/2031.

12. The Responsibility/liability of the owner/occupier or both to maintain Fire safety measures in good condition in all times, in accordance with AP Fire Services Act 1999 and Rules, 2006.

13. Challan Info:

| Challan Number | Challan Date | Challan Amount |
|----------------|--------------|----------------|
| 10108081282026 | 2026-09-11   | 51453          |

The following deficiencies/suggestions are identified by the officers of the department and needs to be attended by the management.

This NOC is issued based on the Recommendation of the SFO, Sompeta Fire Station, on the good working status of fire safety equipment. The Management is requested to ensure the operation of Fire Equipment is in Good working condition at all times and conduct mock drills regularly.

**"Safe School, Safe Hospital & Fire Safety Society-Together for Fire Prevention"**

"सुरक्षित विद्यालय, सुरक्षित अस्पताल एवं अग्नि सुरक्षा के प्रति जागरूक समाज आग की रोकथाम के लिए एक साथ"

"సురక్షిత పాఠశాలలు, సురక్షితమైన ఆసుపత్రులు మరియు అగ్నిమాపక భద్రతపై స్పృహ ఉన్న సమాజం మంటలను నివారించడానికి కలిసి పనిచేస్తాయి."

Your Sincerely,



*T. Mohan Rao*  
(District Disaster Response & Fire Officer,  
Srikakulam District 11/9/2026)

***In case of emergency, please call 101 or 08947 234101 or 9490713525***

Copy to Management Correspondent, M/s J M J English Medium High School, 2-67, Matam Kanchali, Kanchali Mandal, Srikakulam District

Copy to Assistant District Fire Officer Concerned

Copy to Station Fire Officer Concerned